

**SECTION 00 91 13.04 – ADDENDA NUMBER 04**

**PART 1 - GENERAL**

**1.01 PROJECT INFORMATION**

- A. Project Name: Reroofing and Related Work West Woods Upper Elementary, 50 Judson Lane, Farmington, Connecticut
- B. Owner: Town of Farmington, Connecticut
- C. Architect: Jacunski Humes Architects, LLC
- D. Architect Project Number: 2436
- E. Date of Addendum: April 17, 2025.

**1.02 NOTICE TO BIDDERS**

- A. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. All Bidders shall acknowledge receipt of this Addendum in the appropriate space on the Proposal Form.
- C. The date for receipt of bids is unchanged by this Addendum.

**1.03 REQUESTS FOR INFORMATION FROM BIDDERS**

- A. **Question:** Regarding roof area J; in the “Existing Hazardous Material Information”, paragraph 1.1, ‘Roof Description’, it is identified as asphalt shingles but it is identified to become EPDM on drawing R-1.5. Could you please confirm roof area J’s scope?. **Answer:** *Roof area J is an existing built-up roofing system with existing composition believed to be matching Section 003125-1.02-F for ‘TC6’. The new roofing assembly for area J shall be as identified on drawing R-1.5.*

**PART 2 - PRODUCTS (Not Applicable)**

**PART 3 – EXECUTION (Not Applicable)**

**END OF SECTION 00 91 13.04**